

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1624-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2009 Michigan Plumbing Code.

MANUFACTURER:

John Guest USA Inc.

PRODUCT:

John Guest, Speedfit Plumbing System Pipe (PEX) and CTS Twist & Lock Fittings

MANUFACTURER DESIGNATION:

180 Passaic Ave.
Fairfield, NJ 07004

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing Code shall be applicable.
2. Shall be installed in accordance with manufacturer's installation instructions.
3. Shall not be accepted for underground use or within concrete.
4. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission

Irvin J. Poke
Irvin J. Poke, AIA, Director

Robert G. Konyndyk
Robert G. Konyndyk - Chief, Plumbing Division

Effective Date: October 5, 2011